



## **Declaration of Conformity**

| For the following equipmen  | nt:                          | ·                        |                                       |
|---|------------------------------|--------------------------|---------------------------------------|
| Product Name: Din-Rail Switching Power Supply   |                              |                          |                                       |
| Model Designation: DRT-240-X (X=24/48)  |                              |                          |                                       |
| is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:   |                              |                          |                                       |
| RoHS Directive (2011/65/EU)、(EU)2015/863  |                              |                          |                                       |
| Low Voltage Directive (2014/35/EU):   |                              |                          |                                       |
| EN60950-1:2006+A11+A1+A12+A2 TUV certificate No : R50046131   |                              |                          | R50046131                             |
| Electromagnetic Comp<br>EMI (Electro-Magnetic Int<br>Conducted emission / Radi  |                              | /EU) :                   | Class B                               |
| Voltage flicker   | EN61000-3-3:2013             |                          | _                                     |
| EMS (Electro-Magnetic S   |                              |                          |                                       |
| EN55024:2010+A1:2015  | изосримніку)                 |                          |                                       |
| ESD air   | EN61000-4-2:2009             | Level 3                  | 8KV                                   |
| ESD contact   | EN61000-4-2:2009             | Level 2                  | 4KV                                   |
| RF field susceptibility   | EN61000-4-3:2006+A1:2008-    |                          | 10V/m                                 |
| EFT bursts  | EN61000-4-4:2012             | Level 3                  | 2KV/5KHz                              |
| Surge susceptibility  | EN61000-4-5:2014             | Level 3                  | 1KV/Line-Line                         |
| Surge susceptibility  | EN61000-4-5:2014             | Level 3                  | 2KV/Line-Earth                        |
| Conducted susceptibility  | EN61000-4-6:2014             | Level 3                  | 10V                                   |
| Magnetic field immunity   | EN61000-4-8:2010             | Level 4                  | 30A/m                                 |
| Voltage dip, interruption   | EN61000-4-11:2004 >95% dip 0 | .5 periods 30% dip 25 pe | eriods >95% interruptions 250 periods |
| Note:  The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.  For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). |                              |                          |                                       |
| This Declaration is effective from serial number EB9xxxxxxx   |                              |                          |                                       |
| Person responsible for marking this declaration :   |                              |                          |                                       |
| MEAN WELL Enterprises Co., Ltd.   |                              |                          |                                       |
| (Manufacturer Name)   |                              |                          |                                       |
| No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan (Manufacturer Address)   |                              |                          |                                       |
| Johnny Huang/Manager, Certification Center:  (Name / Position)  Alex Tsai/Director, Marketing Department:  (Name / Position)  (Signature)  (Signature)  |                              |                          |                                       |
| Taiwan  | Jul. 22nd, 2019              |                          |                                       |

(Date)

(Place)